
200 AMP H FRAME STRUCTURE/ FARM STYLE SERVICE



NOTES:

SERVICE ENTRANCE STRUCTURE MUST BE BUILT BY THE MEMBER OR CONTRACTOR

- MARSHALL REMC METER SOCKET **MUST** BE GROUNDED
- OUTDOOR DISCONNECTS, AND CONDUIT RISER FURNISHED BY THE MEMBER
- 4 WIRE CONDUCTOR IS RECOMMENDED PAST THE DISCONNECT. CHECK LOCAL BUILDING CODES FOR REQUIREMENTS.

- ALL SERVICE ENTRANCES MUST BE INSPECTED AND PASSED BY THE COUNTY BUILDING INSPECTOR PRIOR TO REMC CONNECTION

